

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7167-0078:158 Page 1 of 1

CATEGORY: Control Unit (Household)

LISTEE: ADEMCO, 165 Eileen Way, Syosset NY 11791
Contact: David Kalmus (516) 921-6704

DESIGN: Models *FA1660C, Vista-40, Vista-50P, Vista-50PEN, Vista-50PENADT, Vista-128B, Vista-128B Plus, *Vista-128BP consisting of model SAVIS128BP sub-assembly and *Vista- 250BP consisting of model SA4142-22 sub-assembly. *Both of these models may be used with Model RES-UL or COM-UL enclosures. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a household fire alarm control units for use with separately listed compatible 2-wire smoke detectors, 2-wire smoke detector bases, RF receivers with smoke detector, 4-wire smoke detectors with 2000 OHM end-of-line resistors and 2-wire polling devices (smoke detectors).

This control unit can generate the temporal code pattern fire alarm signal as required per NFPA 72, 1999 Edition. Refer to manufacturer's Installation Manual for details.

NOTE: Burglary and other non-fire functions were not examined.

*Rev. 10-25-2002 IPI



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

OCTOBER 25, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager